



Film capacitors – Power Factor Correction

Installation and maintenance instructions for PFC capacitors

Series/Type: PhaseCap (B version), PhaseCap HD, WindCap, PhiCap (D version)
Ordering code: B25667B / B25668 / B25669 / B32344D
Date: June 2008
Version: 3

Preliminary data

Installation and maintenance instructions

Read this first!

Read the following »Installation and Maintenance Instructions« carefully before installing a capacitor into your application.

About this manual

The information stated in this manual applies to typical, approved usage. Please refer to our product specifications, or request our approval for your own individual specifications, before installing capacitors.

For your safety!

Disregarding the guidelines in this manual can result in operational failure, bursting and fire. In case of doubt, contact your local EPCOS sales organization or distributor for assistance.

General safety notes for installation and operation

- Ensure you are using the right capacitor type for your application. Please refer to the EPCOS product catalog and application notes for proper selection of capacitors. Please contact EPCOS for any assistance required in selection.
- Maintain good, effective grounding of capacitor enclosures.
- Provide the means to isolate any faulty units/banks in the system.
- Handle capacitor units carefully, as they may be charged even after disconnection due to faulty discharging devices.
- Follow proper engineering practices.
- Do not use the HRC fuses to power up and down the capacitor (otherwise this could lead to the risk of electrical arcing!).
- Also consider terminals of capacitors, connected bus bars and cables and any other devices which are connected with them, as being energized. The device is electrically charged!

Storage and operation conditions

Do not use or store capacitors in a corrosive atmosphere, especially where chloride gas, sulfide gas, acid, alkali, salt or similar substances are present. In a dusty environment, regular maintenance and cleaning, especially of the terminals, is required to avoid a conductive path between phases and/or phases and ground.

Ambient temperature

The ambient temperature category for most standard types is –40/D. This means a max. temperature of 55 °C, an average temperature over 24 hours of 45 °C, and the average temperature in one year should not exceed 35 °C. The maximum casing temperature of 60 °C must not be exceeded. Temperature is one of the main stress factors for polypropylene type capacitors. Temperature has a major influence on the useful life expectancy of the capacitor. For higher temperature requirements, EPCOS offers MKV type capacitors for ambient temperatures of up to 70 °C (with natural cooling).



Preliminary data

Caution!

Exceeding the maximum allowed temperature may set the safety device out of operation.


Capacitors should not be used any longer in case of dents, mechanical or any other kind of damage!

Check the integrity of discharge resistors before installation

Preliminary data

Installation

Mounting the capacitors



Mounting positions

Capacitors installed in a cabinet should be placed on the bottom to ensure the lowest stress temperature possible.

Warning!

Do not install the capacitor in case of dents deeper than 0.5 mm!

PhaseCap, WindCap

The PhaseCap and WindCap capacitor series may be mounted in the vertical **or** horizontal position:




Figure 2: PhaseCap and WindCap in vertical or horizontal mounting position.

PhaseCap HD, PhiCap

The PhaseCap HD and PhiCap capacitors series may be mounted only in the vertical position:




Figure 3: PhaseCap HD and PhiCap in vertical mounting position.

Preliminary data

Mounting conditions

PFC capacitors must be installed in a cool and well ventilated place, and not close to objects that radiate heat such as filter circuit reactors and furnaces, or in the direct sunlight.

Cooling space for capacitors

Make sure that sufficient cooling space is provided (see Figure 4):

- A minimum distance of 20 mm between the capacitors is necessary to maintain sufficient cooling.
- Keep at least 20 mm space above the capacitor and do not attach any mounting components at the crimp or on top. This gap will allow a longitudinal extension of the can in order to ensure that the over-pressure disconnecter can fully extend.




Figure 4: Minimum space over and between the capacitors.

**Using reactors:
cooling space for cables**

If reactors are used in an application, note that they operate at a much higher temperature. The distance between the reactor and capacitor must be large enough so that no reactor heat is conducted via the connection cable to the capacitor, or that heat radiation from the reactor to the capacitor causes overheating.

Fixing threaded bottom stud

The threaded mounting stud is at the bottom of the capacitor:



Preliminary data

Fixing

The threaded bottom stud must be fastened with certain specified torques:

- PhaseCap, WindCap, PhaseCap HD:
M12 bottom stud: torque 10 Nm.
- PhiCap:
M12 bottom stud for diameters > 53 mm: torque 10 Nm
M 8 bottom stud for diameters < 53 mm: torque 4 Nm

Grounding

The M12/M8 bottom stud is used for grounding. Connect it to the ground by cable, or connect the capacitor to any other conductive item which is connected to the ground.

Note!

Suitable connectors have to penetrate existing layers of lacquer to ensure good, constant conductivity and sufficient current carrying capabilities.

If grounding is done via the metal chassis the capacitor is mounted to, then the layer of varnish beneath the washer and nut should be removed.

Connecting

When connecting, avoid bending cable lugs or cables, or the use of other forms of mechanical force on the terminals. Otherwise, leakage could disable the safety device!

Ensure firm fixing of terminals, fixing torque to be applied as per individual specification.

In any case, the maximum specified terminal current may not be exceeded. Please refer to the technical data of the specific series.

Parallel connection of capacitors via the SIGUT terminal is not recommended.

Connecting the supply cable

Cable specification

The connection cable must be of flexible type, material should preferably be copper.

Note!

Do not use solid core cables!

Maximum cable cross section is for

- PhaseCap, PhiCap and WindCap: 16 mm²
- PhaseCap HD: 35 mm².

Further information can be found in the Appendix.

The connection cables to the capacitor should be dimensioned for a current of at least 1.5 times the rated current so that no heat is conducted into the capacitor.

Preliminary data

Maximum terminal currents

Do not exceed the maximum allowable current:

- PhaseCap, WindCap: Max. 50 A total RMS current
- PhaseCap HD: Max. 130 A total RMS current
- PhiCap: Max. 50 A total RMS current

Attaching the supply cable

Attach the supply cable only with the maximum permissible torque values:

- PhaseCap, PhiCap and WindCap: 1.2 Nm
- PhaseCap HD: 2.5 Nm.

Screw driver

Use an appropriate screw driver. The blade must not be wider than 4.5 mm and the diameter of the shank must be less than 4.5 mm in order to fit into the holes with diameter 5.0 mm.




Figure 6: Fixing the supply cable.

Using discharge resistors

Discharge resistors are included in the delivery package, pre-mounted by the factory for PhaseCap B-series and PhiCap D-series.

Discharge resistors are required for discharging of capacitors to protect operating personal (risk of electric shock hazard) and for re-switching capacitors in automatic PFC equipment (phase opposition!).

EPCOS discharge resistors are designed to discharge capacitors down to 75 V or less within 60 seconds.

Make sure that the correct resistor is used for replacement, e.g. ohmic value and push-on connector diameter.

Discharge the capacitor


Before re-switching, capacitors must be discharged to 10% of the rated voltage or below.

A discharge resistor can be easily replaced by pushing it onto the exposed top on the SIGUT terminal.

Preliminary data

Caution!

Discharge and short circuit the capacitor before handling!



Inrush current limitation

Switching LV PFC capacitors can cause high inrush currents of more than 200 times the rated current, especially when they are connected in parallel to others that are already energized. This may cause additional stress to contactors as well as to capacitors and reduce their life cycle.

Inrush currents have a negative effect on power quality, e.g. transients, voltage drop. MKK- and MKP-designs feature high impulse handling capability, inrush current limitation is required, e.g.:

- contactors with pre-charging resistors for pre-loading of capacitors
- serial air coils (approx. 8 turns in the connection cables between contactor and capacitor with a diameter of 10 cm)

IEC 60831 Standard and Reference

According to the IEC 60831 standard, a maximum of 5000 switching operations per year is acceptable. Before considering a higher number of switching operations, please contact EPCOS.

Harmonics

Harmonics are sinusoidal voltages and currents with frequencies that are multiples of a 50 Hz or 60 Hz power supply frequency.

Harmonics result from the operation of electrical loads with non-linear voltage-current characteristics.

They are mainly caused by loads operated with modern electronic devices, such as converters, electrical drives, welding machines and uninterruptible power supplies (UPS).

Ensure that the current through the capacitor doesn't exceed $1.3 \times I_R$. This may indicate heavy presence of harmonics. Check the voltage and current using a true RMS multi-meter.

Ensure that the voltage doesn't exceed $1.1 \times V_R$ and the peak voltage doesn't exceed $1.6 \times V_R$. Use a true rms and peak voltmeter or oscilloscope to check it.

Preliminary data

Attention!	Only power capacitors with reactors – namely de-tuned capacitor banks – should be used in applications with harmonic distortion. Depending on the chosen series resonance frequency, a part of the harmonic current will be absorbed by the power capacitor. The rest of the harmonic current will flow into the grid. The use of power capacitors with reactors reduces harmonic distortion and minimizes the disturbing effects on operation of other loads.
-------------------	--

Avoid resonance conditions	<p>The most important reason for installing de-tuned capacitor banks is to avoid resonance conditions. Resonance conditions may multiply existing harmonics, create power quality problems and damage distribution equipment.</p> <p>Occurrences of resonance should by all means be avoided by appropriate application design!</p> <p>Total RMS capacitor current (incl. fundamental and harmonic currents) specified in the technical data of the specific series must never be exceeded.</p>
-----------------------------------	---

Overpressure Disconnecter	<p>Electrical components do not have unlimited life expectancies; this also applies to self-healing capacitors. As polypropylene-type capacitors seldom produce a pronounced short circuit, HRC fuses or circuit breakers alone do not offer sufficient protection.</p> <p>All capacitors of the PhaseCap, PhaseCap HD, PhiCap and WindCap series are consequently fitted with a disconnecter that responds to overpressure. If numerous electric breakdowns occur at the end of life or as the result of thermal or electric overload (within IEC 831 specification), the formation of gas causes the pressure inside the capacitor case to rise.</p> <p>This causes a change in length because of curvature of the lid or stretching of the expansion bead. Expansion beyond a certain degree will separate the internal wires (tear-off fuses) and disconnect the capacitor from the line.</p>
----------------------------------	---

Caution!	<p>To ensure full functionality of an overpressure disconnecter, observe the following requirements:</p> <ol style="list-style-type: none">1) The elastic metal top must not be impaired:<ul style="list-style-type: none">■ The connecting lines must be flexible leads (cables).■ There must be sufficient space for expansion above the connections (stated for the different models).■ The folding groove must not be retained by clamps.2) The maximum allowed fault current of 10000 A to the UL 810-standard must not be exceeded.3) Stress parameters of the capacitor must be within the IEC60831 specification.
-----------------	---

Preliminary data

Overcurrent / short circuit protection

HRC fuses or moulded case circuit breakers for short circuit protection have to be used. Short circuit protection equipment and connection cable should be dimensioned to handle the 1.5 times rated current of the capacitor permanently.

- HRC fuses do not protect the capacitor against overload. They are only a short circuit protection!
- HRC fuse rating has to be 1.6 ... 1.8 times nominal capacitor current.
- Do not use HRC fuses for switching capacitors (lightning arc!).
- Use thermal/magnetic overcurrent relays for overload protection.

Maintenance

Caution!

Disregarding the following measures may result in severe operation failures, bursting and fire.

- Check tightness of the connections/terminals periodically, two weeks after installation at the latest, and then once every month.
- Clean the terminals/bushings periodically to avoid short circuits due dust or other contamination.
- Check the short circuit protection fuses.
- Take current reading twice a year and compare with nominal current. Use a harmonic analyzer or true effective RMS-meter.
- In case of a current above the nominal current check your application for modifications.
- If a significant increase in the amount of non-linear loads is detected, a consultant has to be called in for a harmonic study.
- In cases of the presence of harmonics, the installation of a de-tuned capacitor bank (reactors) must be considered.
- Check the discharge resistors/reactors and in case of doubt check their function:
 - (1) Power the capacitor up and down.
 - (2) After 60 seconds the voltage between the terminals must decline to less than 75 V.
- Check the temperature of energized capacitors. In case of excessive temperature of individual capacitors, it is recommended to replace this capacitor, as this could be an indication for loss factor increase which is a sign for reaching end of life.

Note!

For detailed information about PFC capacitors and cautions, refer to the latest version of EPCOS PFC Product Profile.

Please note again that these »Installation and Maintenance Instructions« apply to typical specifications. Refer to our product specifications, or request our approval for your specification before installing a capacitor

Preliminary data

Appendix

Connection cable cross section, HRC fuse rating Listed below are recommendations to VDE 0100 for fusing and cable cross sections for three phase power capacitors.

VDE 0100 recommendations Cross-section values mentioned below are guideline values valid for operation under normal conditions and at an ambient temperature of 40 °C. Higher values should be selected if conditions differ from the norm, such as higher temperatures or harmonic distortion.

kvar rating at 400 V kvar	Nominal current A	HRC fuse rating A	Cross section of supply cable mm ²
5	7.4	16	1.5
6.3	9	16	2.5
7.5	10.8	20	2.5
8.3	12	20	2,5
10	14.4	25	4
12.5	18	35	4
15	21.6	35	6
20	29	50	10
25	36	63	16
30	43	80	25
40	58	100	35
50	72	125	35

For other voltage ratings:

230 V table figure · 1.74

440 V table figure · 0.91

480 V table figure · 0.83

525 V table figure · 0.76

The internal wiring of a capacitor bank can be normally done with a lower cross section. Various parameters such as temperature inside cabinet, quality of cable, maximum cable isolation temperature, single or multicore cable and length of cable have to be taken into consideration when selecting the appropriate value.

Vibration resistance The capacitor resistance to vibration corresponds to IEC 68, part 2-6. The following values apply to the capacitor alone.

Preliminary data

Test Conditions

Max. test conditions:

- | | | |
|--------------------------|--------------|--------------|
| ■ Test duration | 2 h | } max. 0.7 g |
| ■ Frequency range | 10 ... 55 Hz | |
| ■ Displacement amplitude | 0.75 mm | |

The connections and the terminals may influence the vibration properties. It is necessary to check the stability when an installed capacitor is exposed to vibration. Irrespective of this, it is not advised to locate capacitors where vibration amplitude could reach maximum levels in strongly vibrating appliances.

Important notes

The following applies to all products named in this publication:

1. Some parts of this publication contain **statements about the suitability of our products for certain areas of application**. These statements are based on our knowledge of typical requirements that are often placed on our products in the areas of application concerned. We nevertheless expressly point out **that such statements cannot be regarded as binding statements about the suitability of our products for a particular customer application**. As a rule, EPCOS is either unfamiliar with individual customer applications or less familiar with them than the customers themselves. For these reasons, it is always ultimately incumbent on the customer to check and decide whether an EPCOS product with the properties described in the product specification is suitable for use in a particular customer application.
2. We also point out that **in individual cases, a malfunction of electronic components or failure before the end of their usual service life cannot be completely ruled out in the current state of the art, even if they are operated as specified**. In customer applications requiring a very high level of operational safety and especially in customer applications in which the malfunction or failure of an electronic component could endanger human life or health (e.g. in accident prevention or life-saving systems), it must therefore be ensured by means of suitable design of the customer application or other action taken by the customer (e.g. installation of protective circuitry or redundancy) that no injury or damage is sustained by third parties in the event of malfunction or failure of an electronic component.
3. **The warnings, cautions and product-specific notes must be observed.**
4. In order to satisfy certain technical requirements, **some of the products described in this publication may contain substances subject to restrictions in certain jurisdictions (e.g. because they are classed as hazardous)**. Useful information on this will be found in our Material Data Sheets on the Internet (www.epcos.com/material). Should you have any more detailed questions, please contact our sales offices.
5. We constantly strive to improve our products. Consequently, **the products described in this publication may change from time to time**. The same is true of the corresponding product specifications. Please check therefore to what extent product descriptions and specifications contained in this publication are still applicable before or when you place an order. We also **reserve the right to discontinue production and delivery of products**. Consequently, we cannot guarantee that all products named in this publication will always be available. The aforementioned does not apply in the case of individual agreements deviating from the foregoing for customer-specific products.
6. Unless otherwise agreed in individual contracts, **all orders are subject to the current version of the "General Terms of Delivery for Products and Services in the Electrical Industry" published by the German Electrical and Electronics Industry Association (ZVEI)**.
7. The trade names EPCOS, BAOKE, Alu-X, CeraDiode, CSSP, CTVS, DSSP, MiniBlue, MKK, MLSC, MotorCap, PCC, PhaseCap, PhaseMod, SIFERRIT, SIFI, SIKOREL, SilverCap, SIMDAD, SIMID, SineFormer, SIOV, SIP5D, SIP5K, ThermoFuse, WindCap are **trademarks registered or pending** in Europe and in other countries. Further information will be found on the Internet at www.epcos.com/trademarks.